



City of Hesperia
Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

HESPERIA OBJECTIVE DESIGN STANDARDS CHECKLIST AND USER'S GUIDE

This user's guide compliments the City of Hesperia's Objective Design Standards. This guide forms a checklist for applicants and City staff to analyze if a proposed project complies with the minimum design standards. A brief description of each standard is listed in the two columns to the left of the table. The full standards are contained in the City's adopted Objective Design Standards. It is an applicant's responsibility to check their project against the City's standards, and to provide a response to each standard on how a proposed project meets or exceeds the standards. It is also the applicant's responsibility to provide the page numbers of the project plans wherein City staff can check if the standard has been met. Once the completed checklist is submitted, the Planning Department will review the responses and determine whether the project does or does not conform to each applicable standard.

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
2.0 Site Planning						
2.1Site Layout						
2.1.a and b	Buildings have public entrances facing the street, with access drives appropriately located. At least 60 percent of frontage is devoted to buildings; up to 40 percent of frontage is devoted to parking, landscaping, and driveways.					
2.1.c	Minimum distance of 10 feet for single story buildings, 15 feet for multi-story buildings.					
2.1. d	On sites with four or more residential buildings, buildings are clustered.					
2.1.	Setbacks are utilized for landscaping.					
2.1.	If adjacent to commercial or industrial uses, parking is located adjacent to these uses and features a landscaped buffer.					



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
2.2 Building Orientation						
2.2.a, b, and c	Entrances are oriented towards non-arterial streets. Front doors are oriented toward street, and elevations emphasize entries, porches, and other living areas.					
2.2. d	Buildings along an arterial provide at least 2 of the following:					
	• Pedestrian level articulation					
	• Ground floor activation					
	• Enhanced landscaping					
2.2. e	Buildings within 15 feet of an adjacent building avoid direct line-of-sight into other units by:					
	• Offset windows					
	• Clerestory windows					
	• Opaque glass					
	• Glass block					
2.2. f	New development protects residents from the sun by at least 1 of the following:					
	• Use of overhangs					
	• Planting trees in front of windows					
	• Covered porches/patios					
2.3 Pedestrian Circulation						
2.3. a	Pedestrian walkways connect throughout the site.					
2.3. b	Walkways are separated from vehicular traffic and utilize appropriate materials.					



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
2.3 c	Pedestrian walkways meet width requirement of 4 feet.					
2.4 Vehicular Circulation						
2.4.1.a, b, c, and d	Vehicular entrances are marked, lead into an entry drive, are limited in number, and utilize appropriate materials.					
2.4.1. e	On lots with more than 150 feet of frontage, landscaped islands are provided.					
2.4.1. f	Alley improvements coincide with site planning.					
2.4.2	Vehicular circulation standards are met.					
2.4.3	Minimum auto court / common court standards are met:					
	• Length					
	• Unit Count & Unit Entrances					
	• Paving / Elevation					
	• Landscaping					



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
2.5 Parking						
General	Surface parking requirements are met. These standards are in addition to the parking and loading standards found in Chapter 16.20, Article 4 of the Hesperia Development Code.					
2.5.1	If provided, parking lots meet design standards.					
2.5.2	If provided, carports meet design standards.					
2.5.3	If provided, tuck-under parking meets design standards.					
2.5.4	Individual garages do not occupy more than 40 percent of a building’s street frontage and are appropriately recessed.					
	In addition, garage doors feature at least 2 of the following:					
	• Enhanced materials					
	• Decorative features					
	• Garage door windows or architectural detailing					
	• Arbors or other projecting features					



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
3.0 Open Space						
3.1 General						
3.1.a and b	Open space areas shall be provided in large, meaningful and usable areas, pursuant to the requirements of Article VII of the Hesperia Development Code. All recreation areas or facilities required by this section shall be maintained by private homeowners’ associations, property owners, or private assessment districts subject to the reviewing authority’s approval.					
	Open space meets locational and dimensional requirements.					
3.2 Common Amenities						
3.2.c	The following major amenities are provided at ratios based on a project’s size (See Table 3.1):					
	• Park					
	• Clubhouse					
	• Rooftop Terrace					
	• Swimming Pool					
	• Gymnasium					
	• An alternative amenity as deemed adequate by the Director					
3.2.d	The following minor amenities are provided at ratios based on a project’s size (See Table 3.1):					
	• Barbecue and picnic area					
	• Sports court					
	• Tot lot with commercial playground equipment					
	• Gazebo or covered seating					
	• Community garden					
	• Courtyard					
	• Aboveground gas fire pit					
	• Spa/hot tub					
	• Community room					
	• Other amenities as deemed adequate by the Director					



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)	
		Yes	No	N/A			
3.3 Private Open Space							
3.3.a, b, and c	Private open space is contiguous to unit it serves and features opaque fencing of at least 42 inches..						
3.3d	Units feature at least 100 square feet of usable open space with dimensions no less than 8 feet and provides 100provides 100 cubic feet of lockable, private storage space if a garage is not provided for the unit.						
3.3.1	Balconies meet locational, dimensional, and material requirements..						
4.0 Mass and Scale							
4.1 Modulation							
4.1b	Vertical façade modulation is provided for buildings 2 or more stories in height with at least 2 of the following:						
	• Change in materials, textures, and colors above ground floor						
	• Functional/decorative projections and recesses						
	• Changes in floor height						
	• Change in materials, textures, and colors below uppermost floor (3+ stories only)						
4.1c	Horizontal façade modulation is provided for buildings as follows:						
	• Minor modulation provided every 60 feet of street-facing façade..						
	• Major modulation provided every 120 feet of street-facing façade..						



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
4.2 Height Modulation						
4.2a	Rooflines are vertically articulated at a minimum of 3 feet every 50 feet.					
4.2b	Buildings 4+ stories feature massing breaks at least every 100 feet.					
4.2c	Rooflines greater than 50 linear feet shall be articulated with at least one of the following:					
	• Change in height of roof ridge/parapet					
	• Change in roof form					
	• Change in angle of roof slope					
4.3 Transitional Massing						
4.3	If adjacent to a single-family zone, a 6-foot wall and at least 2 of the following are provided:					
	• Increased setback					
	• Stepbacks					
	• Offset windows					
	• Transitional height					
4.4 Corner Elements						
4.4	Buildings on a corner must feature at least 2 of the following:					
	• Spire, tower, or dome					
	• Recess or projection.					
	• Building entrance diagonal to intersection					
	• Unique corner features.					
	• Diagonal or curved walls at intersection					
	• Color and material variation					



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
5.0 Materials and Details						
5.1 Materials						
5.1a, b, c, d, e, f.	All buildings feature at least 2 materials on facades fronting a public right-of-way, and all buildings are constructed with durable materials, and all material variation standards are met to produce four-sided architecture.					
5.1.g	For buildings with three or more stories, material, texture, and color variations shall distinguish a building’s base, and/or middle, and/or top.					
5.2 Façade Details						
5.2.a	Façade articulation must be provided through at least 4 of the following:					
	• At least 2 window or door types					
	• Window details					
	• Balconies and/or porches					
	• Decorative light fixtures					
	• Decorative attic/gable vent					
	• Decorative moldings and/or cornices					
	• Trellis and/or arbor structures					
	• Decorative veneer					
5.2.b	Accessory structures and buildings feature the same materials and colors as the primary building.					
5.2.c	Blank facades over 30 feet in length shall include architectural treatments.					



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
5.2.d and e	Standards for expansion joints, exterior stairways, columns, gutters, and other exterior architectural details are followed.					
5.3 Color and Texture						
5.3.a, b, and c	Structures meet primary, accent, and roof color requirements. Developments with multiple buildings feature a variety of color schemes.					
5.4 Unit Entrances						
5.4a	Transitional spaces in the form of stoops, overhangs and porches are provided.					
5.4.b	Primary entrances shall incorporate at least 3 of the following:					
	• Façade projection or recess					
	• Projecting element above entrance					
	• Window detailing					
	• Decorative veneer or siding					
	• Porches or stoops					
	• Material/color variation					
5.5 Doors and Windows						
5.5.a,	Windows are offset at least 1 foot from any windows in adjacent buildings within 15 linear feet.					



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
5.5.b	Windows and doors are recessed or include trim or a windowsill as applicable.					
5.5.c	Windows feature at least 2 of the following:					
	• Variation in window types and/or sizes					
	• Mullion patterning					
	• Moldings					
	• Wood frames					
	• Decorative trim					
	• Shutters					
5.5.d	Windows are double glazed and include screens.					
5.5. e	Doors include doorbells, and viewers.					
6.0 Utilities, Services, Lighting, and Fences						
6.1 Fence, Walls, and Gates						
6.1.a, b and c	Walls are treated on both sides with materials that are durable and consistent with development design.					
6.1.d	Walls and fences are of appropriate height with pillars spaced appropriately where applicable.					



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
6.1.e	Wall/fence sections greater than 50 feet in length fronting a street shall incorporate at least 2 of the following design features:					
	• A minimum 2-foot change in horizontal plane for at least 10 feet.					
	• A minimum 18-inch change in height for at least 10 feet.					
	• A minimum 18-inch high 18-inch-high raised planter for at least half the length of the wall.					
	• Pilasters at 25-foot maximum intervals and at changes in wall planes.					
6.1.f, g and h	Basin, internal fencing, and access gates are appropriate.					
6.1.i	Walls are curved or angled at corner and vehicle entry locations.					
6.2 Exterior Lighting						
6.2.a and b	Lighting is adequate and a minimum of 0.1 foot- candles but shall not exceed 0.5 foot-candle at residential property lines and the right-of-way.					
6.2.c	Fixtures are hooded and compatible with the building architecture.					
6.2.d, e, and f	Pedestrian scale lighting is provided along walkways and a maximum of 15 feet.					



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
6.2.g and h	Adequate lighting of open space and buildings throughout the development.					
6.3 Utility and Mechanical Equipment						
6.3	All utility equipment is appropriately screened as outlined.					
6.4 Refuse Areas						
6.4.a	Enclosures meet waste management standards HMC Ch. 8.04.					
6.4.b	Enclosure is per City detail.					
6.4.c	Enclosure includes the following:					
	• 3 sides of split faced masonry or treated finish					
	• Self-latching opaque metal gate					
	• Decorative trellis/screen gates on top					
7.0 Mixed-Use						
7.1 Vertical Mix of Uses						
7.1.1	Building siting, orientation, and setback standards are met.					



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
7.1.2	Vehicle circulation, access, and parking standards are met.					
7.1.3	Pedestrian circulation standards are met.					
7.1.4	Building organization standards are met.					
7.1.5	Architectural style standards are met.					
7.1.6	Modulation, articulation, and detailing standards are met.					
7.1.7	Site and building entrance standards are met.					
7.1.8	Privacy for residential units is provided					



City of Hesperia

Planning Division
9700 Seventh Avenue
Hesperia, Ca. 92345
760-947-1224

Standard		Conforms? (City)			Response (Applicant)	Page # (Applicant)
		Yes	No	N/A		
7.2 Horizontal Mix of Uses						
7.2.1	Building siting, orientation, and setback standards are met.					
7.2.2	Circulation, access, and parking standards are met.					
7.2.3	Open space standards are met.					
7.2.4	Building organization standards are met.					
7.3 Structured Parking						
7.3.a	Ramps are screened by spandrels.					
7.3.b	Pedestrian and vehicular entrances are distinctly marked.					
7.3.c	Design details for exposed parking structures (must select at least 2):					
	• Alternating facades					
	• Vertical landscaping treatments					
	• Projected elevator shafts and stairwells					
	• Ground floor active uses					
	• Setting back primary mass of structure, if ground floor is activated					